

Annual Checklist for Certification of Migrant Camps

Camp Name	Camp No.	Discussed With	Date
Inspector	Office	New Variance	Date

X - in compliance

NC - not in compliance

V - pre-existing variance in effect

N - new variance in effect S - Square footage under old rules until 1996 NA - not applicable

- _____ 1. No odors, noise, traffic, weeds, depressions, debris
- _____ 2. No livestock within 200' of sleeping and eating facilities
- _____ 3. Space for recreation
- _____ 4. Municipal water or well water tested on _____
- _____ 5. Cold water tap within 100' of units without kitchens
- _____ 6. No common drinking cups
- _____ 7. Excreta and liquid waste disposal
- _____ 8. Housing in good repair
- _____ 9. No cracks to outside
- _____ 10. Flooring smooth
- _____ 11. 50 square feet per person in each sleeping room
- _____ 12. In family housing, 100 square feet per person in kitchen used for sleeping
- _____ 13. Partition if 6 years or older
- _____ 14. Shelf and pole for personal effects
- _____ 15. Seven foot ceilings
- _____ 16. 10% window area, 45% of 10% openable
- _____ 17. Window or skylight in each room, including partitioned areas
- _____ 18. Screening 16 mesh
- _____ 19. Self closing devices on screen doors
- _____ 20. Permanent heaters - living units
- _____ 21. Permanent heaters - all service buildings
- _____ 22. Ceiling or wall type light fixtures
- _____ 23. Washing machines, refrigerators and three- prong outlets effectively grounded
- _____ 24. Correct number of outlets in each habitable room
- _____ 25. Safe wiring
- _____ 26. Light in yard area

- ____ 27. Flush toilets 1 for 15 persons within 200 feet
- ____ 28. Toilet paper holders
- ____ 29. Signs for English and in customary language of occupants
- ____ 30. No privies on site
- ____ 31. No privies within 200' of eating, sleeping area
- ____ 32. Hand washing sinks 1 for 15 persons within 200'
- ____ 33. Dressing space in service unit shower room
- ____ 34. 1 shower head per 15 persons within 200'
- ____ 35. 1 tub per laundry facility
- ____ 36. 1 tub per non-automatic washer
- ____ 37. 1 washer per 30 persons
- ____ 38. Kitchen facilities with stove, oven, refrigerator, tables, chairs
- ____ 39. Sink with hot and cold water in every kitchen
- ____ 40. Central mess facilities in lieu of kitchens
- ____ 41. Fire proof material behind stove units in central mess
- ____ 42. Garbage cans with lids
- ____ 43. Pick up of garbage twice per week
- ____ 44. No vermin
- ____ 45. Clean mattresses with waterproof covers
- ____ 46. Two means of escape-door or 2' x 2' window with push-out screen
- ____ 47. Second exit on second story
- ____ 48. Second stairway or fire escape if second story more than 10' high
- ____ 49. Fire extinguisher
- ____ 50. First-aid kit
- ____ 51. No flammable materials
- ____ 52. No pesticides
- ____ 53. Secure L.P. gas cylinders
- ____ 54. Platform steps
- ____ 55. Handrail
- ____ 56. Safety valve on gas hot water heater
- ____ 57. Smoke Detectors